

CERTIFICATE

(1) Type Examination

(2) **Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC**

(3) Type Examination Certificate Number: **DEKRA 12ATEX0240 X** Issue Number: 1

(4) Equipment: **Programmable Logic Controller System SIMATIC S7-1500, Modules Type 6GK ...**

(5) Manufacturer: **Siemens AG**

(6) Address: **Östliche Rheinbrückenstraße 50, 76187 Karlsruhe, Germany**

(7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report no. 215798800.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0 : 2009

EN 60079-15 : 2010

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This Type Examination Certificate relates only to the design, examination and tests of the specified equipment and not to the manufacturing process and supply of this equipment.

(12) The marking of the equipment shall include the following:



II 3 G Ex nA IIC T4 Gc

This certificate is issued on 9 November 2012 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.

C.G. van Es
Certification Manager

Page 1/3

* Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands
T +31 26 3 56 20 00 F +31 26 3 52 58 00 www.dekra-certification.com Registered Arnhem 09085396

(13) **SCHEDULE**

(14) **to Type Examination Certificate DEKRA 12ATEX0240 X**

Issue No. 1

(15) **Description**

Modules Type 6GK ... for use in SIMATIC S7-1500 Programmable Logic Controller Systems.

The type code, the ambient temperature range and the temperature class of the modules shall be taken from **Table 1**.

Electrical data

The electrical data of the supply and the input and output circuits shall be taken from **Table 1**.

Installation instructions

The manual provided with the equipment shall be followed in detail to assure safe operation.

(16) **Test Report**

No. 2151798800.

(17) **Special conditions for safe use**

1. The modules shall be installed in a suitable enclosure providing a degree of protection of at least IP54 according to EN 60529, taking into account the environmental conditions under which the equipment will be used.
2. When the temperature under rated conditions exceeds 70 °C at the cable or conduit entry point, or 80 °C at the branching point of the conductors, the temperature specification of the selected cable shall be in compliance with the actual measured temperature values.
3. Provisions shall be made to prevent the rated voltage from being exceeded by transient disturbances of more than 40%.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. 215798800.

(13) **SCHEDULE**

(14) **to Type Examination Certificate DEKRA 12ATEX0240 X**

Issue No. 1

Table 1

Description	Type/MLFB No.	Temp. code	Ambient Range	Technical Data	Supply Volt.
CM1542-5	6GK7542-5DX00-0XE0	T4	0...+60°C	15V / max. 200mA	15 Vdc
CP1543-1	6GK7543-1AX00-0XE0	T4	0...+60°C	15V / max. 350mA	15 Vdc